

POTTED PLANTS REALLY DO CLEAN INDOOR AIR

RESEARCH SUMMARY, JUNE, 2007

Prof. Margaret Burchett, Dr Jane Tarran, Dr Fraser Torpy

Plants and Indoor Environmental Quality Group

Faculty of Science, UTS

Email: Margaret.Burchett@uts.edu.au (Mob: 0405 499 350)

Why worry about urban air pollution?

Urban air pollution (mainly from fossil fuel combustion) is an international health problem. In Sydney alone, air pollution causes an estimated 2,400 deaths p.a.¹. In addition, urban dwellers spend an amazing 90% of our time indoors, so that's where we meet all the air pollution^{2,3} - and here air pollution is even higher than outdoors^{3,4}. Why? Because the outdoor-derived load (of nitrogen, sulfur and carbon oxides, organics, particulates etc.) diffuses indoors and is augmented by indoor-derived contaminants. The main class of these is volatile organic compounds (VOCs), outgassing from other petroleum-based products, such as 'synthetics' in furnishings, detergents, paints, printers, 'air fresheners' and the like. The chemical mixtures, even at imperceptible levels, can cause 'building-related illness' and symptoms of headache, sore eyes, nose and throat, or nausea^{5,6,7}. Dust, moulds and flueless gas appliance emissions can add to indoor pollution loads.

Indoor plants as air cleansers

International research, over more than two decades, shows that indoor potted-plants can significantly reduce all these types of air-borne pollutants, arising from either outdoor or indoor sources, and can also reduce noise levels^{8,9,10,11}. Studies have also shown that, where indoor plants have been installed, staff wellbeing is improved with sick-leave absences reduced by over 60%, presumably as the result of both air-cleansing and aesthetic properties that promote staff wellbeing^{12,13,14}.

VOC removal from indoor air was first demonstrated in pilot screening studies by NASA, in a program to test the uses of plants in space missions^{15,16,17}. Following this work, we have conducted detailed bench-top test-chamber investigations on VOC removal in nine species of internationally used potted plants, and shown that they can eliminate high doses of VOCs in about 24 hours, powered mainly by the root-zone microorganisms, that are nourished by the plants (a symbiotic microcosm)^{18,19,20}. We also conducted a 'real-world' study using 60 UTS staff offices, with three planting regimes, which showed that, whenever total VOC loads rose above about 100 ppb (ie equivalent to about half an aspirin in an Olympic pool), even the smallest planting regime (6 shelf-sized plants), was enough to kick in and reduce concentrations by up to 75%, always to below 100 ppb once more. They were equally effective in air-conditioned or non air-conditioned offices. We are currently researching the *minimum* amount of plant material needed to be effective for air cleansing^{21,22,23}. *No 'jungle' was used or necessary!*

Together, the numerous studies, from both our own research and a number of different sources around the world, show conclusively that the potted-plant microcosm can greatly improve indoor air quality by removing many major pollutants. It therefore represents an adaptive, self-regulating, portable, flexible, low-cost, sustainable and beautiful, air-cleansing system, that can be used in any building, and can complement any engineering measures, which are not normally aimed at lowering gaseous pollutants at all.

References

1. New South Wales Environment Protection Authority (NSW EPA) (2006) (pers. comm.) and reported in The Daily Telegraph, 24/02/06.
2. D. Cavallo et al. (1997) "Exposure to air pollution in home of subjects living in Milan", Proceedings of Healthy Buildings/IAQ '97, Vol. 3, 141-145.
3. Environment Australia (EA) (2003) "BTEX Personal Exposure Monitoring in Four Australian Cities", Technical Paper No. 6: EA, 2003. Canberra, ACT, Australia.
4. S. K. Brown (1997) "Volatile organic compounds in indoor air: sources and control", Chemistry in Australia, Vol. 64 (Jan/Feb), 10-13.
5. P. Carrer et al. (1999) "Home and workplace complaints and symptoms in office workers and correlation with indoor air pollution", Proceedings the 8th International Conference on Indoor Air Quality and Climate, Vol. 1, 129-134.
6. World Health Organisation (WHO) 2000 "The Right to Healthy Indoor Air – Report on a WHO Meeting, Bilthoven", NL, European HEALTH Targets 10, 13.
7. L. Mølhave and M. Krzyzanowski (2003) "The right to healthy indoor air: status by 2002", Indoor Air, Vol. 13, Supplement 6, 50-53.
8. P. R. Costa and R. W. James (1999) "Air conditioning and noise control using vegetation", Proceedings of the 8th International Conference on Indoor Air Quality and Climate, Vol. 3, 234-239.
9. M. Coward et al. (1996) "Pilot Study to Assess the Impact of Green Plants on NO₂ Levels in Homes", Building Research Establishment Note N154/96, Watford, UK.
10. J.-H. Lee and W.-K. Sim (1999) "Biological absorption of SO₂ by Korean native indoor species", In, M.D. Burchett et al. (eds) "Towards a New Millennium in People-Plant Relationships, Contributions from International People-Plant Symposium", Sydney, 101-108.
11. V. I. Lohr and C. H. Pearson-Mims (1996) "Particulate matter accumulation on horizontal surfaces in interiors: influence of foliage plants", Atmospheric Environment, Vol. 30, 2565-8.
12. T. Yoneyama et al. (2002) "Metabolism and detoxification of nitrogen dioxide and ammonia in plants", In, K. Omasa et al. (eds) Air Pollution and Plant Biotechnology – Prospects for Phytomonitoring and Phytoremediation, Springer, Tokyo, Japan, 221-234.
13. J. Bergs (2002) "Effect of healthy workplaces on well-being and productivity of office workers", Proceedings of International Plants for People Symposium, Floriade, Amsterdam, NL.
14. T. Fjeld (2002) "The effects of plants and artificial daylight on the well-being and health of office workers, school children and health-care personnel", Proceedings of International Plants for People Symposium, Floriade, Amsterdam, NL.
15. B. C. Wolverton, A. Johnson and K. Bounds (1989) "Interior Landscape Plants for Indoor Air Pollution Abatement", Final Report, NASA Stennis Space Centre MS, USA.
16. Wolverton Environmental Services Inc. (1991) "Removal of Formaldehyde from Sealed Experimental Chambers, by *Azalea*, *Poinsettia* and *Dieffenbachia*", Res. Rep. No. WES/100/01-91/005.
17. B. C. Wolverton and J. D. Wolverton (1993) "Plants and soil microorganisms: removal of formaldehyde, xylene, and ammonia from the indoor environment", Journal of the Mississippi Acad. Sci., Vol. 38 (2), 11-15.
18. J. Tarran et al. (2002) "Quantification of the Capacity of Indoor Plants to Remove Volatile Organic Compounds under Flow-through Conditions", Final Report to Horticulture Australia Ltd, Sydney.
19. R. A. Wood et al. (2002) "Potted-plant/growth media interactions and capacities for removal of volatiles from indoor air", Journal of Horticultural Science and Biotechnology, Vol. 77 (1), 120-129.
20. R. L. Orwell et al. (2004) "Removal of benzene by the indoor plant/ substrate microcosm and implications for air quality", Water, Air, and Soil Pollution, Vol. 157, 193-207.
21. M. D. Burchett et al. (2005) "Improving Indoor Environmental Quality Through the Use of Indoor Potted Plants", Final Report to Horticulture Australia Ltd, Sydney.
22. R. A. Wood et al. (2006) "The potted-plant microcosm substantially reduces indoor air VOC pollution: I. Office field-study", Water, Air, and Soil Pollution, Vol. 175, 163-180.
23. R. L. Orwell et al. (2006) "The potted-plant microcosm substantially reduces indoor air VOC pollution: II. Laboratory study", Water, Air, and Soil Pollution, Vol. 177, 59-80.